



**CENTRAL COAST WATER AUTHORITY
 POLONIO PASS WATER TREATMENT PLANT
 WATER QUALITY TABLE
 COVERING THE REPORTING PERIOD OF JANUARY-DECEMBER 2018**

Please see last page for key to abbreviations.

Parameter	Units	State MCL	PHG (MCLG)	State DLR	Range Average	TREATED	SOURCE	Major Sources in Drinking Water
						CCWA	STATE WATER	

PRIMARY STANDARDS--Mandatory Health-Related Standards

CLARITY (a)

Combined Filter Effluent Turbidity (a)	NTU	TT=<1 NTU every 4 hours TT=95% of samples <0.3 NTU	Range	0 - 0.13	NA	Soil runoff
			%	100%	NA	

INORGANIC CHEMICALS

Aluminum	mg/L	1 (b)	0.6	0.05	Range	ND - 0.095	ND - 0.14	Erosion of natural deposits; residual from some surface water treatment processes
					Average	0.058	0.088	

DISTRIBUTION SYSTEM MONITORING

Total Chlorine Residual	mg/L	MRDL = 4.0	MRDLG = 4.0	NA	Range	1.76 - 3.2	NA	Drinking water disinfectant added for treatment
					Average	2.32	NA	
Total Coliform Bacteria (c)	--	5.0% of monthly samples	(0)	--	Range	0	NA	Naturally present in the environment
					Average	0	NA	
					Highest	0%	NA	
Total Trihalomethanes (d)	ug/L	80	NA	(0.5)	Range	27 - 50	NA	By-product of drinking water chlorination
					Average	39	NA	
					Highest LRAA	42.8	NA	
Haloacetic Acids (d)	ug/L	60	NA	(1) (e)	Range	8.3 - 12	NA	By-product of drinking water chlorination
					Average	10	NA	
					Highest LRAA	13.1	NA	

SECONDARY STANDARDS--Aesthetic Standards

Chloride	mg/L	500 (j)	NA	(1)	Range	39 - 140	34 - 142	Runoff/leaching from natural deposits; seawater influence
					Average	81	78	
Color	ACU	15 (j)	NA	(3)	Range	ND	30	Naturally occurring organic materials
					Average	ND	30	
Corrosivity (Aggressivity Index) (i)	SU	non-corrosive	NA	(0.1)	Range	11	11	
					Average	11	11	
Iron, Total	mg/L	0.3 (j)	NA	0.1	Range	ND	0.17	Leaching from natural deposits; industrial wastes
					Average	ND	0.17	
Manganese, Total	ug/L	50 (j)	NA	(2)	Range	ND	22	
					Average	ND	22	
Odor Threshold	TON	3 (j)	NA	(1)	Range	2	2	Naturally occurring organic materials
					Average	2	2	
Specific Conductance	uS/cm	1600 (j)	NA	NA	Range	294 - 592	105 - 702	Substances that form ions when in water; seawater influence
					Average	481	451	
Sulfate	mg/L	500 (j)	NA	(0.5)	Range	55	30	Runoff/leaching from natural deposits; industrial wastes
					Average	55	30	
Total Dissolved Solids (TDS)	mg/L	1000 (j)	NA	(10)	Range	220	190	Runoff/leaching from natural deposits
					Average	220	190	
Turbidity (Monthly) (a)	NTU	5 (j)	NA	(0.1)	Range	ND - 0.12	ND - 10.2	Soil runoff
					Average	0.05	1.73	

ADDITIONAL PARAMETERS (Unregulated)

2-Methylisoborneol	ng/L	NA	NA	(1)	Range	ND - 1	ND - 2	
					Average	0.4	0.6	
Alkalinity (Total) as CaCO3 equivalents	mg/L	NA	NA	(2)	Range	44 - 78	46 - 86	Runoff/leaching from natural deposits; seawater influence
					Average	61	66	
Calcium	mg/L	NA	NA	(1)	Range	14	15	Runoff/leaching from natural deposits; seawater influence
					Average	14	15	

Chromium, Hexavalent	ug/L	NA	0.02	NA	Range	0.058	0.064	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits
					Average	0.058		
Geosmin	ng/L	NA	NA	(1)	Range	ND - 1	ND - 2	
					Average	0.6	0.6	
Hardness (Total) as CaCO ₃	mg/L	NA	NA	(3)	Range	62 - 140	58 - 142	Leaching from natural deposits
					Average	96	96	
Heterotrophic Plate Count (f)	CFU/mL	TT	NA	NA	Range	0 - 1	NA	Naturally present in the environment
					Average	0	NA	
Magnesium	mg/L	NA	NA	(0.1)	Range	7.7	8.0	Runoff/leaching from natural deposits; seawater influence
					Average	7.7	8.0	
pH	SU	NA	NA	(0.1)	Range	7.8 - 8.7	7.6 - 9.45	Runoff/leaching from natural deposits; seawater influence
					Average	8.3	8.5	
Potassium	mg/L	NA	NA	(1)	Range	1.8	1.9	Runoff/leaching from natural deposits; seawater influence
					Average	1.8	1.9	
Sodium	mg/L	NA	NA	(1)	Range	40	33	Runoff/leaching from natural deposits; seawater influence
					Average	40	33	
Total Organic Carbon (TOC) (g)	mg/L	TT	NA	(0.3)	Range	1.6 - 3.2	2.4 - 5	Various natural and man made sources
					Average	2.1	3.3	

ABBREVIATIONS AND NOTES

Footnotes:

- (a) Turbidity (NTU) is a measure of the cloudiness of the water and it is a good indicator of the effectiveness of our filtration system. Monthly turbidity values are listed in the Secondary Standards section.
- (b) Aluminum has a Secondary MCL of 0.2 ppm.
- (c) Total coliform MCLs: Systems that collect ≥ 40 samples/month no more than 5.0% of the monthly samples may be Total Coliform positive. Systems that collect < 40 samples per month no more than 1 positive sample per month may be Total Coliform positive.
Fecal coliform/E. coli MCLs: The occurrence of 2 consecutive Total Coliform positive samples, one of which contains fecal coliform/E. coli, constitutes an acute MCL violation.
- (d) Compliance based on the running quarterly annual average of distribution system samples.
- (e) Monochloroacetic Acid (MCAA) has a DLR of 2.0 ug/L while the other four Haloacetic Acids have DLR's of 1.0 ug/L.
- (f) Pour plate technique
- (g) TOCs are taken at the treatment plant's combined filter effluent.
- (h) State MCL is 45 mg/L as NO₃, which equals 10 mg/L as N.
- (i) AI ≥ 12.0 = Non-aggressive water
AI (10.0 - 11.9) = Moderately aggressive water
AI ≤ 10.0 = Highly aggressive water
Reference: ANSI/AWWA Standard C400-93 (R98)
- (j) Secondary MCL

Abbreviations

ACU = Apparent Color Units
 CCWA = Central Coast Water Authority
 CFU/ml = Colony Forming Units per milliliter
 DLR = Detection Level for purposes of Reporting
 MCL = Maximum Contaminant Level
 MCLG = Maximum Contaminant Level Goal
 MRDL = Maximum Residual Disinfectant Level
 MRDLG = Maximum Residual Disinfectant Level Goal
 NA = Not Applicable
 NTU = Nephelometric Turbidity Units
 pCi/L = PicoCuries per liter
 PHG = Public Health Goal
 ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$)
 ppm = parts per million, or milligrams per liter (mg/L)
 TON = Threshold Odor Number
 TT = Treatment Technique
 LRAA = Locational Running Annual Average

Central Coast Water Authority 2018 Non-Detect Table

Parameter	Units	State or Federal MCL [MRDL]	PHG (MCLG) [MRDLG]	State DLR (MRL)	Raw Source Water		Treated Water		Major Sources in Drinking Water
					<i>State Water Project</i>		<i>Polonio Pass WTP</i>		
					Most Recent Sample Date	Result	Most Recent Sample Date	Result	
MICROBIOLOGICAL									
Cryptosporidium	Oocysts/200L	TT	(0)	NA	11/20/2018	0	NC	NC	Naturally present in the environment
Giardia	Cysts/200L	TT	(0)	NA	11/20/2018	0	NC	NC	Naturally present in the environment
RADIONUCLIDES									
Gross Alpha Particle	pCi/L	15	(0)	3	5/2/2018	ND	5/2/2018	ND	Erosion of natural deposits
Gross Beta Particle (g)	pCi/L	50 (g)	(0)	4	5/2/2018	ND	5/2/2018	ND	Decay of natural and man-made deposits
ORGANIC CHEMICALS									
Regulated VOC's plus Lists 1&3 (EPA 524.2)									
1,1,1,2-Tetrachloroethane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
1,1,1-Trichloroethane	ug/L	200	1000	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from metal degreasing sites and other factories; manufacture of food wrappings
1,1,2,2-Tetrachloroethane	ug/L	1	0.1	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial and agricultural chemical factories; solvent used in production of TCE, pesticides, varnish and lacquers
1,1,2-Trichloro-1,2,2-trifluoroethane	mg/L	1.2	4	0.01	5/2/2018	ND	6/26/2018	ND	Discharge from metal degreasing sites and other factories; dry cleaning solvent; refrigerant
1,1,2-Trichloroethane	ug/L	5	0.3	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories
1,1-Dichloroethane	ug/L	5	3	0.5	5/2/2018	ND	6/26/2018	ND	Extraction and degreasing solvent; used in manufacture of pharmaceuticals, stone, clay and glass products; fumigant
1,1-Dichloroethylene	ug/L	6	10	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories
1,1-Dichloropropene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
1,2,3-Trichlorobenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
1,2,3-Trichloropropane	ng/L	5 (e)	0.7	5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.
1,2,4-Trichlorobenzene	ug/L	5	5	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from textile-finishing factories
1,2,4-Trimethylbenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Ethylene dibromide	ng/L	50	10	20	5/2/2018	ND	5/2/2018	ND	Discharge from petroleum refineries; underground gas tank leaks; banned nematocide that may still be present in soils due to runoff and leaching from grain and fruit crops
1,2-Dichlorobenzene	ug/L	600	600	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories
1,2-Dichloroethane	ng/L	500	400	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories
1,2-Dichloropropane	ug/L	5	0.5	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories; primary component of some fumigants

1,3,5-Trimethylbenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
1,3-Dichlorobenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
1,3-Dichloropropane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
1,4-Dichlorobenzene	ug/L	5	6	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories
2,2-Dichloropropane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
2-Butanone	ug/L	NA	NA	5	5/2/2018	ND	6/26/2018	ND	
2-Chlorotoluene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
4-Methyl-2-pentanone	ug/L	NA	NA	(5)	5/2/2018	ND	6/26/2018	ND	
Benzene	ug/L	1	0.15	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from plastics, dyes and nylon factories; leaching from gas storage tanks and landfills
Bromobenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Bromochloromethane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Bromomethane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Carbon disulfide	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Carbon tetrachloride	ng/L	500	100	500	5/2/2018	ND	6/26/2018	ND	Discharge from chemical plants and other industrial activities
Chlorobenzene	ug/L	70	200	(0.5)	5/2/2018	ND	6/26/2018	ND	
Chloroethane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Chloromethane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
cis-1,2-Dichloroethylene	ug/L	6	100	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories; major biodegradation by-product of TCE and PCE groundwater contamination
cis-1,3-Dichloropropene	ug/L	NA	NA		5/2/2018	ND	6/26/2018	ND	Runoff/leaching from nematocide used on croplands
Dibromomethane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Diisopropyl ether	ug/L	NA	NA	(3)	5/2/2018	ND	6/26/2018	ND	
Dichlorodifluoromethane	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Ethylbenzene	ug/L	300	300	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from petroleum refineries; industrial chemical factories
tert-Butyl ethyl ether	ug/L	NA	NA	(3)	5/2/2018	ND	6/26/2018	ND	
Hexachlorobutadiene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Isopropylbenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
m,p-Xylenes	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	Discharge from petroleum and chemical factories; fuel solvent
Dichloromethane	ug/L	5	4	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from pharmaceutical and chemical factories; insecticide
Methyl tert-butyl ether (a)	ug/L	13 (b)	13	3	5/2/2018	ND	6/26/2018	ND	Leaking underground storage tanks; discharge from petroleum and chemical factories
Naphthalene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
n-Butylbenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	

n-Propylbenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
o-Xylene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	Discharge from petroleum and chemical factories; fuel solvent
p-Chlorotoluene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
p-Isopropyltoluene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
sec-Butylbenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Styrene	ug/L	100	0.5	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from rubber and plastic factories; leaching from landfills
tert-Amyl methyl ether	ug/L	NA	NA	(3)	5/2/2018	ND	6/26/2018	ND	
tert-Butylbenzene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	
Tetrachloroethylene	ug/L	5	0.06	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
Toluene	ug/L	150	150	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from petroleum and chemical factories; underground gas tank leaks
1,3-Dichloropropene, Total	ng/L	500	200	500	5/2/2018	ND	6/26/2018	ND	Runoff/leaching from nematocide used on croplands
Total Xylenes	mg/L	1.750	1.8	0.0005	5/2/2018	ND	6/26/2018	ND	Discharge from petroleum and chemical factories; fuel solvent
trans-1,2-Dichloroethylene	ug/L	10	60	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial chemical factories; minor biodegradation by-product of TCE and PCE groundwater contamination
trans-1,3-Dichloropropene	ug/L	NA	NA	(0.5)	5/2/2018	ND	6/26/2018	ND	Runoff/leaching from nematocide used on croplands
Trichloroethylene	ug/L	5	1.7	0.5	5/2/2018	ND	6/26/2018	ND	Discharge from metal degreasing sites and other factories
Trichlorofluoromethane	ug/L	150	1300	5	5/2/2018	ND	6/26/2018	ND	Discharge from industrial factories; degreasing solvent; propellant and refrigerant
Vinyl chloride	ng/L	500	50	500	5/2/2018	ND	6/26/2018	ND	Leaching from PVC piping; discharge from plastics factories; biodegradation by-product of TCE and PCE groundwater contamination
Organochlorine Pesticides/PCBs (EPA 505)									
Alachlor	ug/L	2	4	1	5/2/2018	ND	5/2/2018	ND	Runoff from herbicide used on row crops
Aldrin	ug/L	NA	NA	(0.01)	5/2/2018	ND	5/2/2018	ND	
Chlordane	ng/L	100	30	100	5/2/2018	ND	5/2/2018	ND	Residue of banned insecticide
Dieldrin	ug/L	NA	NA	(0.2)	5/2/2018	ND	5/2/2018	ND	
Endrin	ug/L	2	0.3	0.1	5/2/2018	ND	5/2/2018	ND	Residue of banned insecticide and rodenticide
Heptachlor	ng/L	10	8	10	5/2/2018	ND	5/2/2018	ND	Residue of banned insecticide
Heptachlor epoxide	ng/L	10	6	10	5/2/2018	ND	5/2/2018	ND	Breakdown of heptachlor
Lindane	ng/L	200	32	200	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor	ug/L	30	0.09	10	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
PCB 1016 Aroclor (as DCB)	ug/L	0.5	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals
PCB 1221 Aroclor (as DCB)	ug/L	0.5	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals
PCB 1232 Aroclor (as DCB)	ug/L	0.5	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals

PCB 1242 Aroclor (as DCB)	ug/L	0.5	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals
PCB 1248 Aroclor (as DCB)	ug/L	0.5	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals
PCB 1254 Aroclor (as DCB)	ug/L	0.5	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals
PCB 1260 Aroclor (as DCB)	ug/L	0.5	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals
PCB's, Total	ng/L	500	90	500	5/2/2018	ND	5/2/2018	ND	Runoff from landfills; discharge of waste chemicals
Toxaphene	ug/L	3	0.03	1	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from insecticide used on cotton and cattle
Aldicarb (EPA 531.2)									
3-Hydroxycarbofuran	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Aldicarb	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Aldicarb sulfone	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Aldicarb sulfoxide	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Baygon	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Carbaryl	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Carbofuran	ug/L	18	0.7	5	5/2/2018	ND	5/2/2018	ND	Leaching of soil fumigant used on rice and alfalfa, and grape vineyards
Methiocarb	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Methomyl	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Oxamyl	ug/L	50	26	20	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from insecticide used on field crops, fruits and ornamentals, especially apples, potatoes, and tomatoes
Diquat and Paraquat (EPA 549.2)									
Diquat	ug/L	20	6	4	5/2/2018	ND	5/2/2018	ND	Runoff from herbicide use for terrestrial and aquatic weeds
Paraquat	ug/L	NA	NA	(2)	5/2/2018	ND	5/2/2018	ND	
EDB and DBCP (EPA 551.1)									
Dibromochloropropane	ng/L	200	1.7	10	5/2/2018	ND	5/2/2018	ND	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
Ethylene dibromide	ng/L	50	10	20	5/2/2018	ND	5/2/2018	ND	Discharge from petroleum refineries; underground gas tank leaks; banned nematocide that may still be present in soils due to runoff and leaching from grain and fruit crops
Chlorophenoxy Herbicides (EPA 515.4)									
2,4,5-T	ug/L	NA	NA	(0.2)	5/2/2018	ND	5/2/2018	ND	
2,4,5-TP	ug/L	50	3	1	5/2/2018	ND	5/2/2018	ND	Residue of banned herbicide
2,4-Dichlorophenoxyacetic acid	ug/L	70	20	10	5/2/2018	ND	5/2/2018	ND	Runoff from herbicide used on row crops, range land, lawns, and aquatic weeds
2,4-DB	ug/L	NA	NA	2	5/2/2018	ND	5/2/2018	ND	
3,5-Dichlorobenzoic acid	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Acifluorfen	ug/L	NA	NA	(0.2)	5/2/2018	ND	5/2/2018	ND	

Bentazon	ug/L	18	200	2	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from herbicide used on beans, peppers, corn, peanuts, rice, and ornamental grasses
Dalapon	ug/L	200	790	10	5/2/2018	ND	5/2/2018	ND	Runoff from herbicide used on rights-of-way, and crops and landscape maintenance
Dicamba	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
Dichlorprop	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Dinoseb	ug/L	7	14	2	5/2/2018	ND	5/2/2018	ND	Runoff from herbicide used on soybeans, vegetables, and fruits
Pentachlorophenol	ug/L	1	0.3	0.2	5/2/2018	ND	5/2/2018	ND	Discharge from wood preserving factories, cotton and other insecticidal/herbicidal uses
Picloram	ug/L	500	166	1	5/2/2018	ND	5/2/2018	ND	Herbicide runoff
DCPA (total Mono & Diacid Degradates)	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
Other Synthetic Organics									
Dioxin	pg/L	30	0.05	5	5/2/2018	ND	5/2/2018	ND	Emissions from waste incineration and other combustion; discharge from chemical factories
Endothall	ug/L	100	94	45	6/18/2018	ND	6/18/2018	ND	Runoff from herbicide use for terrestrial and aquatic weeds; defoliant
Glyphosate	ug/L	700	900	25	5/2/2018	ND	5/2/2018	ND	Runoff from herbicide use
Semivolatiles (EPA 525.2)									
2,4-Dinitrotoluene	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
Acenaphthylene	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
alpha-Chlordane	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Anthracene	ug/L	NA	NA	(0.02)	5/2/2018	ND	5/2/2018	ND	
Atrazine	ug/L	1	0.15	0.5	5/2/2018	ND	5/2/2018	ND	Runoff from herbicide used on row crops and along railroad and highway right-of-ways
Benzo (a) anthracene	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Benzo (a) pyrene	ng/L	200	7	100	5/2/2018	ND	5/2/2018	ND	Leaching from linings of water storage tanks and distribution mains
Benzo (b) fluoranthene	ug/L	NA	NA	(0.02)	5/2/2018	ND	5/2/2018	ND	
Benzo (g,h,i) perylene	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Benzo (k) fluoranthene	ug/L	NA	NA	(0.02)	5/2/2018	ND	5/2/2018	ND	
Bromacil	ug/L	NA	NA	(0.2)	5/2/2018	ND	5/2/2018	ND	
Butachlor	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Butylbenzylphthalate	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Chrysene	ug/L	NA	NA	(0.02)	5/2/2018	ND	5/2/2018	ND	
Di (2-Ethylhexyl) phthalate	ug/L	4	12	3	5/2/2018	ND	5/2/2018	ND	Discharge from rubber and chemical factories; inert ingredient in pesticides
Di-(2-Ethylhexyl) adipate	ug/L	400	200	5	5/2/2018	ND	5/2/2018	ND	Discharge from chemical factories
di-n-Butylphthalate	ug/L	NA	NA	(1)	5/2/2018	ND	5/2/2018	ND	

Diazinon	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
Dibenz (a,h) anthracene	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Diethylphthalate	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Dimethoate	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
Dimethylphthalate	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Fluoranthene	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
Fluorene	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
gamma-Chlordane	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Hexachlorobenzene	ug/L	1	0.03	0.5	5/2/2018	ND	5/2/2018	ND	Discharge from metal refineries and agricultural chemical factories; by-product of chlorination reactions in wastewater
Hexachlorocyclopentadiene	ug/L	50	2	1	5/2/2018	ND	5/2/2018	ND	Discharge from chemical factories
Indeno (1,2,3,c,d) Pyrene	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Isophorone	ug/L	NA	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	
Metribuzin	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Molinate	ug/L	20	1	2	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from herbicide used on rice
Phenanthrene	ug/L	NA	NA	(0.04)	5/2/2018	ND	5/2/2018	ND	
Propachlor	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Pyrene	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Simazine	ug/L	4	4	1	5/2/2018	ND	5/2/2018	ND	Herbicide runoff
Thiobencarb (a)	ug/L	70 (h)	42	1	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from herbicide used on rice
trans-Nonachlor	ug/L	NA	NA	(0.05)	5/2/2018	ND	5/2/2018	ND	
Trifluralin	ug/L	NA	NA	(0.1)	5/2/2018	ND	5/2/2018	ND	
INORGANIC CHEMICALS									
Antimony, Total	ug/L	6	1	6	5/2/2018	ND	5/2/2018	ND	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic, Total	ug/L	10	0.004	2	5/2/2018	ND	5/2/2018	ND	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium, Total	mg/L	1	2	0.1	5/2/2018	ND	5/2/2018	ND	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Beryllium, Total	ug/L	4	1	1	5/2/2018	ND	5/2/2018	ND	Discharge from metal refineries, coal-burning factories, and electrical, aerospace, defense industries
Cadmium, Total	ug/L	5	0.04	1	5/2/2018	ND	5/2/2018	ND	Internal corrosion of galvanized pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories, and metal refineries; runoff from waste batteries and paints
Chromium, Total	ug/L	50	(100)	10	5/2/2018	ND	5/2/2018	ND	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Copper (a)	mg/L	1 (c) (f)	0.3	0.05	5/2/2018	ND	5/2/2018	ND	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Cyanide	ug/L	150	150	100	5/2/2018	ND	5/2/2018	ND	Discharge from steel/metal, plastic and fertilizer factories
Fluoride	mg/L	2	1	0.1	5/2/2018	ND	5/2/2018	ND	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Hydroxide as OH	mg/L	NA	NA	(2)	5/2/2018	ND	5/2/2018	ND	
Lead	ug/L	(c)	0.2	5	5/2/2018	ND	5/2/2018	ND	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Mercury	ug/L	2	1.2	1	5/2/2018	ND	5/2/2018	ND	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland
Nickel, Total	ug/L	100	12	10	5/2/2018	ND	5/2/2018	ND	Erosion of natural deposits; discharge from metal factories
Nitrate as Nitrogen	mg/L	10 (h)	10	0.4	5/2/2018	ND	5/2/2018	ND	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrite as Nitrogen	mg/L	1	1	0.4	5/2/2018	ND	5/2/2018	ND	Runoff and leaching from fertilizer use; leach-ing from septic tanks and sewage; erosion of natural deposits
Perchlorate	ug/L	6 (d)	1	4	5/2/2018	ND	5/2/2018	ND	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares.
Selenium, Total	ug/L	50	30	5	5/2/2018	ND	5/2/2018	ND	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Silver, Total	ug/L	100 (f)	NA	(0.5)	5/2/2018	ND	5/2/2018	ND	Industrial Discharges
Thallium, Total	ug/L	2	0.1	1	5/2/2018	ND	5/2/2018	ND	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Zinc, Total	mg/L	5 (f)	NA	(0.02)	5/2/2018	ND	5/2/2018	ND	Runoff/leaching from natural deposits; industrial wastes

ABBREVIATIONS AND FOOTNOTES

Abbreviations

DCPA	Dimethyl Tetrachloroterephthalate	NC	Not Collected
DLR	Detection Limits for purposes of Reporting	ND	None Detected
MCL	Maximum Contaminant Level	pCi/L	picoCuries per Liter
MCLG	Maximum Contaminant Level Goal	PHG	Public Health Goal
MFL	Million Fibers per Liter	ppb	Parts per billion
MRDL	Maximum Residual Disinfectant Level	ppm	Parts per million
MRDLG	Maximum Residual Disinfectant Level Goal	ppt	Parts per trillion
MRL	Minimum Reporting Limit	ppq	Parts per quadrillion
NA	Not Applicable		

Footnotes

- (a) Copper, MTBE, and thiobencarb have both primary and secondary standards.
MTBE has a secondary MCL of 5 ppb.
- (b)
- (c) Lead and copper are regulated as a Treatment Technique under the Lead and Copper Rule. It requires systems to take water samples at the consumers' tap. The action levels, which trigger water systems into taking treatment steps if exceeded in more than 10% of the tap water samples, are 1.3 ppm for copper and 15 ppb for lead.
- (d) The State primary MCL for perchlorate was set at 6 ppb effective October 18, 2007. Perchlorate reporting level is 2 ppb.
- (e) 1,2,3-Trichloropropane is an unregulated contaminant with a notification level of 0.005 ppb.
- (f) Secondary MCL.
- (g) Gross beta particle activity MCL is 4 millirem/year annual dose equivalent to the total body or any internal organ. 50pCi/L is used as a screening level.
- (h) Thiobencarb has a secondary MCL of 1 ppb.