

# Central Coast Water Authority



## Process Control Benchsheet

Date: *Tuesday, January 02, 2018*

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
<i>Treated Water Tanks</i>	11.1	8.34	0.06	2.55		0.50	0.04	54	90	0.7	0.005	1	299	Absent	
<i>Shandon T/O</i>															3
<i>Tank Site #2</i>	10.0	8.37	0.06	2.28		0.51	0.05	56	90	0.8	0.004	1	302	Absent	
<i>Chorro</i>	12.0	8.34	0.06	2.11		0.50	0.05	54	90	0.8	0.005	1	302	Absent	93
<i>Lopez T/O</i>															0
<i>Guadalupe T/O</i>															66
<i>Santa Maria T/O</i>	12.3	8.34	0.05	1.99		0.50	0.06	56	90	0.8	0.005	1	301	Absent	920
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	12.3	8.35	0.05	1.93		0.49	0.06	54	92	0.9	0.005	1	299	Absent	
<i>Vandenberg T/O</i>	12.1	8.39	0.05	1.93		0.50	0.04	58	96	0.9	0.004	1	301	Absent	182
<i>Tank Site #7</i>	12.6	8.35	0.05	2.10		0.48	0.03	58	92	0.9	0.004	1	300	Absent	
<i>Buellton T/O</i>	12.7	8.28	0.05	2.16		0.49	0.04	56	92	0.9	0.006	1	299	Absent	41
<i>Solvang T/O</i>	12.6	8.35	0.05	2.17		0.47	0.04	56	92	0.9	0.007	1	299	Absent	32
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 27.9 MG

Samples Taken: 01/02/2018  
 Samples Analyzed: 1/4/2018 3:05:00 PM  
 Sampler: David Bazzell  
 Analyst: Louise Hickok

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 01/10/2018