

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, January 6, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
Treated Water Tanks	14.0	8.23	0.13	2.95		0.52	0.00	60	76	0.8	0.006	1	253	Absent	
Shandon T/O															0
Tank Site #2	12.4	8.25	0.12	2.74		0.52	0.00	60	86	0.8	0.006	1	246	Absent	
Chorro	13.4	8.29	0.13	2.70		0.52	0.00	60	84	0.8	0.006	1	246	Absent	146
Lopez T/O	13.8	8.32	0.16	2.66		0.52	0.00	58	84	0.9	0.006	1	244	Absent	69
Guadalupe T/O	14.0	8.38	0.11	2.61		0.52	0.01	60	82	0.9	0.006	1	244	Absent	61
Santa Maria T/O	14.0	8.36	0.11	2.64		0.51	0.00	60	82	0.9	0.005	1	242	Absent	589
Golden State T/O															10
Tank Site #5	13.8	8.37	0.11	2.55		0.50	0.00	60	80	0.9	0.005	1	238	Absent	
Vandenberg T/O	14.1	8.39	0.11	2.71		0.52	0.00	60	84	0.9	0.006	1	237	Absent	195
Tank Site #7	14.3	8.34	0.12	2.42		0.45	0.00	62	82	0.9	0.010	1	236	Absent	
Buellton T/O	15.0	8.36	0.12	2.32		0.44	0.01	62	84	0.9	0.011	1	235	Absent	12
Solvang T/O	12.0	8.36	0.14	2.38		0.46	0.00	66	82	0.9	0.011	1	234	Absent	47
Santa Ynex ID#1 T/O	15.1	8.45	0.13	2.21		0.44	0.04	64	84	0.9	0.012	1	233	Absent	49

Average Plant Flow for Sample Week = 13.8 MG

Samples Taken: 01/06/2020  
 Samples Analyzed: 1/8/2020 10:22:00 AM  
 Sampler: Eric Kiedking, David Bazzell  
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 01/10/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, January 13, 2020

	Temp °C	pH	NTU	Chlorine (mg/L) Total	Chlorine (mg/L) Free	NH3-N (mg/L) Total	NH3-N (mg/L) Free	Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	December Deliveries
Treated Water Tanks	12.4	8.07	0.13	3.00		0.53	0.00	64	96	1.0	0.007	1	309	Absent	
Shandon T/O															0
Tank Site #2	12.7	8.20	0.11	2.61		0.43	0.05	64	96	1.0	0.007	1	296	Absent	
Chorro	13.9	8.28	0.11	2.51		0.44	0.06	64	96	1.0	0.007	1	291	Absent	146
Lopez T/O	14.6	8.31	0.11	2.57		0.44	0.07	66	94	1.0	0.008	1	290	Absent	69
Guadalupe T/O	15.0	8.40	0.11	2.35		0.42	0.07	64	92	0.9	0.007	1	284	Absent	61
Santa Maria T/O	15.0	8.41	0.10	2.37		0.42	0.07	66	92	0.9	0.008	1	282	Absent	589
Golden State T/O															10
Tank Site #5	15.0	8.52	0.13	2.21		0.47	0.05	62	90	0.9	0.009	1	271	Absent	
Vandenberg T/O	14.9	8.49	0.11	2.44		0.46	0.00	64	88	0.9	0.008	1	269	Absent	195
Tank Site #7	15.3	8.50	0.10	2.41		0.43	0.00	62	86	0.9	0.006	1	253	Absent	
Buellton T/O	16.0	8.50	0.12	2.11		0.41	0.01	62	84	0.9	0.011	1	251	Absent	12
Solvang T/O	15.3	8.52	0.12	1.79		0.40	0.06	60	86	0.9	0.021	1	210	Absent	47
Santa Ynex ID#1 T/O															49

Average Plant Flow for Sample Week = 9.1 MG

Samples Taken: 01/13/2020  
 Samples Analyzed: 1/15/2020 10:00:00 AM  
 Sampler: David Bazzell  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 01/17/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Tuesday, January 21, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
Treated Water Tanks	12.0	8.15	0.13	3.10		0.54	0.00	62	96	1.0	0.006	1	305	Absent	
Shandon T/O															0
Tank Site #2	12.1	8.16	0.13	2.57		0.52	0.03	64	96	1.0	0.006	1	309	Absent	
Chorro	13.4	8.25	0.13	2.66		0.53	0.03	64	96	1.0	0.006	1	310	Absent	146
Lopez T/O	14.1	8.24	0.19	2.53		0.52	0.04	64	96	1.0	0.007	1	312	Absent	69
Guadalupe T/O	14.7	8.34	0.14	2.33		0.50	0.05	64	98	1.0	0.007	1	312	Absent	61
Santa Maria T/O	14.7	8.37	0.12	2.35		0.50	0.05	66	98	1.0	0.007	1	312	Absent	589
Golden State T/O															10
Tank Site #5	14.8	8.41	0.12	2.26		0.51	0.06	66	98	1.0	0.008	1	312	Absent	
Vandenberg T/O	14.8	8.43	0.13	2.62		0.50	0.00	68	98	1.0	0.008	1	312	Absent	195
Tank Site #7	15.3	8.54	0.13	2.51		0.49	0.00	66	92	0.9	0.009	1	282	Absent	
Buellton T/O	15.8	8.58	0.11	2.31		0.45	0.00	64	92	0.9	0.010	1	275	Absent	12
Solvang T/O	15.6	8.64	0.10	2.09		0.43	0.01	64	88	0.9	0.012	1	269	Absent	47
Santa Ynex ID#1 T/O															49

Average Plant Flow for Sample Week = 8.4 MG

Samples Taken: 01/21/2020  
 Samples Analyzed: 1/23/2020 8:00:00 AM  
 Sampler: Eric Kieding  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 01/28/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, January 27, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
Treated Water Tanks	13.5	8.17	0.10	3.00		0.57	0.01	68	94	1.2	0.006	1	324	Absent	
Shandon T/O															0
Tank Site #2	12.9	8.23	0.10	2.61		0.56	0.05	70	96	1.1	0.006	1	321	Absent	
Chorro	14.2	8.31	0.10	2.57		0.53	0.03	68	98	1.1	0.006	1	316	Absent	146
Lopez T/O	13.9	8.32	0.12	2.32		0.49	0.03	68	94	1.1	0.005	1	314	Absent	69
Guadalupe T/O	14.5	8.36	0.13	2.16		0.48	0.05	70	94	1.1	0.006	1	311	Absent	61
Santa Maria T/O	14.4	8.38	0.10	2.21		0.47	0.04	72	96	1.1	0.007	1	312	Absent	589
Golden State T/O															10
Tank Site #5	14.7	8.47	0.09	2.29		0.48	0.03	68	94	1.0	0.009	1	311	Absent	
Vandenberg T/O	14.6	8.46	0.09	2.54		0.50	0.00	70	94	1.0	0.006	1	311	Absent	195
Tank Site #7	15.2	8.58	0.13	2.41		0.48	0.00	72	98	1.0	0.009	1	315	Absent	
Buellton T/O	15.5	8.60	0.10	2.37		0.47	0.00	74	98	1.0	0.007	1	312	Absent	12
Solvang T/O	15.0	8.64	0.10	2.40		0.46	0.00	70	94	1.0	0.009	1	306	Absent	47
Santa Ynex ID#1 T/O															49

Average Plant Flow for Sample Week = 9.5 MG

Samples Taken: 01/27/2020  
 Samples Analyzed: 1/29/2020 8:55:00 AM  
 Sampler: James Thompson  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 01/31/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, February 3, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	January Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
<i>Treated Water Tanks</i>	13.4	8.24	0.11	3.13		0.57	0.00	78	106	1.0	0.008	1	345	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	12.2	8.23	0.12	2.76		0.51	0.01	74	104	1.1	0.007	1	338	Absent	
<i>Chorro</i>	13.5	8.26	0.11	2.67		0.49	0.00	76	104	1.1	0.006	1	338	Absent	151
<i>Lopez T/O</i>	14.2	8.43	0.11	2.59		0.51	0.02	78	102	1.1	0.007	1	335	Absent	70
<i>Guadalupe T/O</i>	14.8	8.28	0.13	2.43		0.51	0.04	76	106	1.1	0.004	1	337	Absent	58
<i>Santa Maria T/O</i>	14.8	8.44	0.10	2.55		0.48	0.00	78	100	1.1	0.007	1	334	Absent	330
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	14.5	8.43	0.10	2.33		0.47	0.01	72	100	1.1	0.009	1	334	Absent	
<i>Vandenberg T/O</i>	14.6	8.42	0.11	2.58		0.50	0.00	76	98	1.1	0.007	1	329	Absent	191
<i>Tank Site #7</i>	15.2	8.55	0.13	2.36		0.47	0.00	76	96	1.1	0.007	1	312	Absent	
<i>Buellton T/O</i>	15.7	8.60	0.10	2.39		0.47	0.00	72	94	1.1	0.009	1	312	Absent	11
<i>Solvang T/O</i>	14.7	8.63	0.11	2.33		0.44	0.00	72	96	1.0	0.009	1	312	Absent	38
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 10.8 MG

Samples Taken: 02/03/2020  
 Samples Analyzed: 2/5/2020 9:00:00 AM  
 Sampler: Manuel Espinoza, Jeff Tice  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 02/14/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, February 10, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	January Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
<i>Treated Water Tanks</i>	14.5	8.16	0.10	3.10		0.56	0.00	74	108	0.9	0.006	1	338	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	11.7	8.20	0.11	2.81		0.50	0.00	76	108	1.0	0.007	1	345	Absent	
<i>Chorro</i>	12.9	8.25	0.10	2.75		0.50	0.00	76	110	0.9	0.006	1	352	Absent	151
<i>Lopez T/O</i>	14.0	8.28	0.10	2.54		0.50	0.02	78	112	1.0	0.007	1	351	Absent	70
<i>Guadalupe T/O</i>	14.4	8.33	0.11	2.49		0.50	0.00	78	110	0.9	0.007	1	351	Absent	58
<i>Santa Maria T/O</i>	14.5	8.35	0.12	2.48		0.51	0.02	80	114	0.9	0.007	1	352	Absent	330
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	14.5	8.37	0.12	2.47		0.47	0.00	80	112	1.0	0.010	1	352	Absent	
<i>Vandenberg T/O</i>	14.5	8.37	0.11	2.55		0.51	0.00	80	112	1.0	0.007	1	351	Absent	191
<i>Tank Site #7</i>	15.3	8.55	0.13	2.28		0.45	0.00	74	98	1.2	0.010	1	322	Absent	
<i>Buellton T/O</i>	15.7	8.59	0.11	2.05		0.40	0.00	74	98	1.1	0.010	1	320	Absent	11
<i>Solvang T/O</i>	15.0	8.58	0.16	1.87		0.40	0.00	72	100	1.1	0.010	1	316	Absent	38
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 11.4 MG

Samples Taken: 02/10/2020  
 Samples Analyzed: 2/12/2020 9:45:00 AM  
 Sampler: Garrett Nelson, Jeff Tice  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 02/14/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Tuesday, February 18, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	January Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
<i>Treated Water Tanks</i>	14.8	8.22	0.12	3.08		0.55	0.00	76	106	0.8	0.007	1	333	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	13.4	8.26	0.11	2.67		0.51	0.00	76	108	0.8	0.006	1	334	Absent	
<i>Chorro</i>	14.1	8.26	0.12	2.57		0.50	0.00	78	108	0.8	0.008	1	333	Absent	151
<i>Lopez T/O</i>	14.3	8.26	0.10	2.59		0.49	0.00	78	110	0.8	0.007	1	330	Absent	70
<i>Guadalupe T/O</i>	14.5	8.29	0.12	2.40		0.45	0.01	78	110	0.7	0.007	1	329	Absent	58
<i>Santa Maria T/O</i>	14.4	8.30	0.12	2.36		0.45	0.01	76	106	0.7	0.009	1	330	Absent	330
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	14.4	8.41	0.11	2.26		0.44	0.00	78	106	0.8	0.007	1	331	Absent	
<i>Vandenberg T/O</i>	14.3	8.40	0.13	2.49		0.49	0.00	78	104	0.8	0.010	1	333	Absent	191
<i>Tank Site #7</i>	15.4	8.58	0.12	2.11		0.42	0.02	80	108	1.1	0.013	1	343	Absent	
<i>Buellton T/O</i>	15.8	8.66	0.12	2.17		0.40	0.00	78	106	1.2	0.012	1	340	Absent	11
<i>Solvang T/O</i>	15.2	8.72	0.12	2.05		0.39	0.01	76	102	1.2	0.014	1	335	Absent	38
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 12.6 MG

Samples Taken: 02/18/2020  
 Samples Analyzed: 2/20/2019 9:00:00 AM  
 Sampler: David Bazzell  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 02/24/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, February 24, 2020

	Temp °C	pH	NTU	Chlorine (mg/L) Total	Chlorine (mg/L) Free	NH3-N (mg/L) Total	NH3-N (mg/L) Free	Alkalinity mg/L as CaCO3	Hardness mg/L as CaCO3	Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	January Deliveries
<i>Treated Water Tanks</i>	15.0	8.21	0.13	3.12		0.55	0.00	76	102	0.8	0.006	1	332	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	13.9	8.31	0.13	2.64		0.50	0.00	74	106	0.8	0.006	1	335	Absent	
<i>Chorro</i>	14.8	8.33	0.11	2.62		0.49	0.00	78	106	0.8	0.007	1	337	Absent	151
<i>Lopez T/O</i>	15.1	8.34	0.12	2.56		0.48	0.00	76	106	0.8	0.006	1	340	Absent	70
<i>Guadalupe T/O</i>	15.2	8.37	0.13	2.50		0.46	0.00	78	108	0.8	0.006	1	341	Absent	58
<i>Santa Maria T/O</i>	15.2	8.35	0.11	2.53		0.46	0.00	80	108	0.8	0.007	1	338	Absent	330
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	14.8	8.40	0.11	2.33		0.42	0.00	88	108	0.8	0.010	1	333	Absent	
<i>Vandenberg T/O</i>	14.7	8.40	0.10	2.64		0.47	0.00	88	108	0.8	0.008	1	335	Absent	191
<i>Tank Site #7</i>	15.4	8.58	0.52	2.11		0.38	0.00	94	112	1.0	0.015	1	347	Absent	
<i>Buellton T/O</i>	15.8	8.67	0.12	2.09		0.39	0.00	86	112	1.0	0.014	1	352	Absent	11
<i>Solvang T/O</i>	15.4	8.70	0.13	2.00		0.37	0.00	86	112	1.1	0.018	1	349	Absent	38
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 12.4 MG

Samples Taken: 02/24/2020  
 Samples Analyzed: 2/27/2020 9:00:00 AM  
 Sampler: Eric Kieding  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 03/02/2020



# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, March 2, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
<i>Treated Water Tanks</i>	15.6	8.18	0.10	3.06		0.56	0.00	68	98	0.7	0.007	1	327	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	15.2	8.23	0.11	2.80		0.52	0.00	68	100	0.6	0.007	1	330	Absent	
<i>Chorro</i>	16.0	8.28	0.11	2.78		0.51	0.00	68	100	0.6	0.006	1	328	Absent	156
<i>Lopez T/O</i>	16.0	8.30	0.10	2.71		0.50	0.00	68	100	0.6	0.005	1	328	Absent	66
<i>Guadalupe T/O</i>	15.6	8.36	0.12	2.66		0.50	0.00	70	102	0.7	0.008	1	332	Absent	19
<i>Santa Maria T/O</i>	15.6	8.39	0.11	2.63		0.49	0.00	72	102	0.8	0.006	1	333	Absent	520
<i>Golden State T/O</i>															5
<i>Tank Site #5</i>	15.1	8.43	0.11	2.43		0.49	0.04	76	104	0.8	0.008	1	336	Absent	
<i>Vandenberg T/O</i>	15.0	8.41	0.10	2.70		0.50	0.00	76	106	0.9	0.007	1	334	Absent	214
<i>Tank Site #7</i>	15.5	8.50	0.25	2.29		0.41	0.00	82	110	0.9	0.018	1	338	Absent	
<i>Buellton T/O</i>	14.8	8.55	0.10	2.16		0.40	0.00	80	112	0.8	0.013	1	338	Absent	13
<i>Solvang T/O</i>	14.7	8.63	0.11	2.10		0.38	0.00	80	112	0.8	0.019	1	336	Absent	46
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 11.8 MG

Samples Taken: 03/02/2020  
 Samples Analyzed: 3/4/2020 9:00:00 AM  
 Sampler: James Thompson  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 03/06/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, March 9, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
Treated Water Tanks	15.8	8.09	0.10	2.97		0.53	0.00	64	90	0.5	0.005	1	327	Absent	
Shandon T/O															0
Tank Site #2	15.3	8.22	0.11	2.85		0.54	0.00	66	96	0.6	0.006	1	327	Absent	
Chorro	16.2	8.23	0.10	2.72		0.52	0.00	70	96	0.6	0.005	1	328	Absent	156
Lopez T/O	16.1	8.29	0.10	2.75		0.51	0.00	68	96	0.6	0.007	1	329	Absent	66
Guadalupe T/O	16.1	8.32	0.10	2.58		0.49	0.00	70	96	0.7	0.007	1	331	Absent	19
Santa Maria T/O	16.0	8.33	0.12	2.57		0.50	0.00	70	98	0.7	0.006	1	332	Absent	520
Golden State T/O															5
Tank Site #5	15.6	8.35	0.10	2.47		0.46	0.00	70	98	0.7	0.008	1	330	Absent	
Vandenberg T/O	15.7	8.36	0.11	2.69		0.51	0.00	72	98	0.8	0.007	1	332	Absent	214
Tank Site #7	15.8	8.51	0.12	2.06		0.39	0.00	78	104	0.9	0.029	1	344	Absent	
Buellton T/O	16.1	8.52	0.10	2.00		0.38	0.00	78	108	0.9	0.023	1	347	Absent	13
Solvang T/O	15.8	8.54	0.12	2.02		0.38	0.00	78	108	0.9	0.028	1	348	Absent	46
Santa Ynex ID#1 T/O															0

Average Plant Flow for Sample Week = 12.0 MG

Samples Taken: 03/09/2020  
 Samples Analyzed: 3/11/2020 1:20:00 PM  
 Sampler: Manuel Espinoza, Sean Rogers  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 03/13/2020

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, March 16, 2020

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
<i>Treated Water Tanks</i>	15.0	8.22	0.09	3.09		0.58	0.00	62	92	0.3	0.006	1	316	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	15.3	8.39	0.09	3.01		0.57	0.00	62	94	0.3	0.006	1	318	Absent	
<i>Chorro</i>	15.9	8.39	0.09	2.96		0.55	0.00	60	94	0.3	0.006	1	316	Absent	156
<i>Lopez T/O</i>	16.4	8.32	0.10	2.78		0.53	0.00	62	92	0.3	0.005	1	320	Absent	66
<i>Guadalupe T/O</i>	16.4	8.47	0.10	2.68		0.52	0.00	64	94	0.3	0.005	1	322	Absent	19
<i>Santa Maria T/O</i>	16.3	8.49	0.10	2.76		0.52	0.00	64	94	0.3	0.008	1	322	Absent	520
<i>Golden State T/O</i>															5
<i>Tank Site #5</i>	16.0	8.53	0.10	2.52		0.49	0.00	66	94	0.4	0.011	1	324	Absent	
<i>Vandenberg T/O</i>	15.9	8.48	0.09	2.74		0.51	0.00	64	94	0.4	0.007	1	324	Absent	214
<i>Tank Site #7</i>	16.0	8.48	0.10	2.42		0.44	0.00	70	96	0.6	0.015	1	330	Absent	
<i>Buellton T/O</i>	16.3	8.54	0.10	2.37		0.44	0.00	70	96	0.7	0.013	1	330	Absent	13
<i>Solvang T/O</i>	15.9	8.55	0.09	2.33		0.44	0.00	72	98	0.7	0.022	1	329	Absent	46
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 12.9 MG

Samples Taken: 03/16/2020  
 Samples Analyzed: 3/18/2020 11:08:00 AM  
 Sampler: David Bazzell, Jeff Tice, Sean  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 03/19/2020