

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, January 6, 2025

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
Treated Water Tanks	14.4	8.17	0.10	3.47		0.71	0.06	70	94	0.9	0.008	1	273	Absent	
Shandon T/O															0
Tank Site #2	13.7	8.34	0.09	3.10		0.72	0.10	70	94	0.7	0.009	1	270	Absent	
Chorro	15.1	8.36	0.09	3.08		0.70	0.09	70	96	0.6	0.008	1	269	Absent	111
Lopez T/O															0
Guadalupe T/O	16.2	8.48	0.09	2.91		0.63	0.07	70	94	0.5	0.010	1	265	Absent	43
Santa Maria T/O	16.2	8.46	0.10	2.85		0.63	0.09	70	94	0.4	0.013	1	265	Absent	346
Golden State T/O															0
Tank Site #5	16.3	8.39	0.10	2.06		0.51	0.12	68	90	0.3	0.041	1	251	Absent	
Vandenberg T/O	16.2	8.38	0.09	2.21		0.42	0.00	68	90	0.3	0.006	1	247	Absent	209
Tank Site #7															
Buellton T/O															17
Solvang T/O															0
Santa Ynex ID#1 T/O															0

Average Plant Flow for Sample Week = 7.9 MG

Samples Taken: 01/06/2025
 Samples Analyzed: 1/8/2025 1:30:00 PM
 Sampler: David Bezzell, Sean Rogers
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 01/13/2025